



1 2 BROADWAY

EVACUATION PROCEDURES

FIRE ALARM ACTIVATION

The Fire Safety Director will be in communication and direct the evacuation or the sheltering in place of all persons in the affected floor(s). All persons on the fire floor, the floor above and floor below the fire floor must relocate to at least four floors below the affected floor(s) using stairs.

For Example: If the fire is on the 22nd floor, the floor above and

